

RHSC and DCN



MAIL TYPE  
General Correspondence

MAIL NUMBER  
MPX-GC-021525

REFERENCE NUMBER  
MPX-GC-021525

---

## Environmental Matrix Meeting 28.09.17

---

From Mr Ken Hall - Multiplex Construction Europe  
To (5) David Black - Wallace Whittle (+4 more...)  
Cc (4) Mr Keith McIntee - Multiplex Construction Europe (+3 more...)  
Sent Thursday, October 5, 2017 13:19:21 +0000  
Status N/A

### FILE ATTACHMENTS (1)

File Name
 Mark up from 28.09.17.pdf

### ATTRIBUTES

Attribute 1 Stage 3 - RHSC & DCN Construction Phase  
Attribute 2 33. M&E Building Services

### MESSAGE

Confirmation of Discussions.

1.0 11 points noted and attached to be captured in the current Rev 10 version in for RDD. Revised version 10 to be circulated to Kamil who will then discard the current copy. Update to be complete and issued by 13.10.17.

2.0 TUV SUD requested a review line by line, Motts noted if TUV SUD can confirm a check has been made line by line then there was no requirement to do a line by line check. TUV SUD confirmed a line by line check had been carried out in their office. Item closed.

3.0 Feedback from Motts that subject to the 11No clarifications required for Rev 010 this concludes the review of the matrix. Next stage is to use the matrix at site to check off against what is installed within the rooms.

4.0 Multi bed rooms were not discussed at this meeting. Matrix will require to be updated once the changes are instructed.

5.0 All touchdown bases have 1000 lux been added under previous revisions (shown in pink). It was noted LG2 does not require touchdowns to have 1000 lux. TUV SUD to review how the 1000lux is being provided, and by who?

6.0 Schedule of accommodation to be checked in relation to references plantroom references . Matrix to be updated.

7.0 With rev 10 review now concluded, Motts noted the following updates to be scheduled out:

- (i) Schedule Accommodation Changes
- (ii) Change Controls
- (iii) 4 bedded wards (as item 4 above)
- (iv) Plantroom Numbering (as item 6 above)